

IEC 61850 Certificate - IEC 61850 Certificate #6495

SEL-451-6

07/28/2023 12:45 PM - Herbert Falk

Status:	Approved	Test Document:	Edition 2 Server Test Procedures version 2.0.6
Priority:	Normal	Certificate Name:	23-3003_DNV_SEL-451-6_variants_ServerEd2_Certificate.pdf
61850 Edition:	Edition 2	Certificate Hash:	SHA256: 8FCBD302FF0E27BB2E5C0D50DA534 00B76C0F9A5311EC135BACFD24A387 5EA7E
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	SEL-451-6	Vendor Artifact Hash:	
Address:		Umbrella Organization:	
Product:	SEL-451-6	Optional Reservation Test:	Yes
HW Version:	MB6E	Serial Number:	
SW Version:	SEL-451-6-R405/IEC 61850 library ID: 49DD6E42	Publisher Legacy Variants:	-
Key Words:		Publisher Preferred Rates:	-
Test Procedure Version:	2.0.6	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), Service Tracking (B15), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	-
Certificate/Result Reviewer:	Herbert Falk	Subscriber Preferred Variants:	
Approval Date:	07/28/2023	Subscriber Preferred Rates:	-
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			
Protection, Automation, and Bay Control System with Sampled Values or TiDL Technology.			

Files

23-3003_DNV_SEL-451-6_variants_ServerEd2_Certificate.pdf	124 KB	07/28/2023	Herbert Falk
--	--------	------------	--------------