

61850-7-5 and 61850-7-500 - IEC61850-7-5 #6496

Typo in section 13.3

08/02/2023 08:54 AM - Keith Gray

Status: New	Start date: 08/02/2023
Priority: Normal	Due date:
Assignee:	% Done: 0%
Category:	
Target version:	
Source:	TF 7-5 Project document:
Category: Document Error	Related TISSUE:
Description	
<p>The first paragraph of section 13.3 has a typo in the 3rd line. See the strikethrough and update below.</p> <p>Most protection functions (LN Pxxx) provide in case of operation Start (DO Str) and Operate (DO Op) if applicable. All the Op are collected by the LN PTRC (named in Figure 29 PTRC1) which provides a common Trip (DO Str Tr) for the circuit breaker. In addition, there is also a common Start (Str) and Operate (Op) as non-tripping information for other LNs and as information option for the HMI. The basic use of PTRC is shown in Figure 29.</p>	