

Parameters to enforce the checking of interlocking and synchronism

08/02/2023 11:14 AM - Michael Haecker

Status:	In Progress	Start date:	08/02/2023
Priority:	Normal	Due date:	
Assignee:	Michael Haecker	% Done:	0%
Category:			
Target version:			
Source:		TF 7-5 Project document:	IEC 61850-7-500
Category:	New section	Related TISSUE:	
Description			
Enhancement of the datamodel with two new setting parameters 'EnfItI' and 'EnfSyn'. The concept was already developed in TF "Control between functions". cross reference to #6499 Update of table "Dependance of checking interlocking conditions on the control service parameters and on the server operational configuration"			

History

#1 - 09/14/2023 08:19 AM - Keith Gray

- Related TISSUE set to <https://iec61850.tissue-db.com/tissue/1874>
- TF 7-5 Project document IEC 61850-7-500 added

#2 - 09/14/2023 08:19 AM - Keith Gray

- Related TISSUE deleted (<https://iec61850.tissue-db.com/tissue/1874>)

#3 - 10/05/2023 08:57 AM - Keith Gray

- Status changed from New to In Progress