

IEC 61850 Certificate - IEC 61850 Certificate #6501

K-IED T100

08/03/2023 03:32 PM - Herbert Falk

Status:	Approved	Test Document:	Edition 2 Server Test Procedures version 2.0.6
Priority:	Normal	Certificate Name:	23TC200578_Kyongbo_IED_K-IED-T100_Server_Ed2_KERI.pdf
61850 Edition:	Edition 2	Certificate Hash:	SHA256: 07B716A789587478C376F1550E08EA8 CC97847B49842038401C684DB74743F 78
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Kyongbo Electric Co, Ltd	Vendor Artifact Hash:	
Address:	5, Seongsuil-ro, 12ga-gil, Seongdong-gu, Seoul, Republic of Korea	Umbrella Organization:	
Product:	K-IED T100	Optional Reservation Test:	Yes
HW Version:	MCU version: 2.00/DSP version: 1.00	Serial Number:	
SW Version:	COMM version: 2.00	Publisher Legacy Variants:	-
Key Words:	Relay	Publisher Preferred Rates:	-
Test Procedure Version:	2.0.6	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), Service Tracking (B15), Setting Group (B4), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	-
Certificate/Result Reviewer:	Herbert Falk	Subscriber Preferred Variants:	
Approval Date:	08/03/2023	Subscriber Preferred Rates:	-
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Korea Electrotechnology Research Institute (A)		
Description Protection IED			

Files

23TC200578_Kyongbo_IED_K-IED-T100_Server_Ed2_KERI.pdf	507 KB	08/03/2023	Herbert Falk
---	--------	------------	--------------