

IEC 61850 Certificate - IEC 61850 Certificate #6502

Easergy MiCOM P443 Fast Multifunction Distance Protection Relay

08/03/2023 03:39 PM - Herbert Falk

Status:	Approved	Test Document:	Edition 2 Server Test Procedures version 2.0.6
Priority:	Normal	Certificate Name:	23-D 089191 0043_Schneider_P443_IEC61850Ed2_Server_Certificate.pdf
61850 Edition:	Edition 2	Certificate Hash:	SHA256: F936030D2CA84B9F41EA1727EF69C4 95C1FD6CC98998631B55533C43C7B5 A9B6
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Schneider Electric Industries SAS	Vendor Artifact Hash:	
Address:	35 rue Joseph Monier, 92500 Rueil Malmaison, France	Umbrella Organization:	
Product:	Easergy MiCOM P443 Fast Multifunction Distance Protection Relay	Optional Reservation Test:	No
HW Version:	M	Serial Number:	P44331QA6M0K60M
SW Version:	K6	Publisher Legacy Variants:	-
Key Words:	Distance	Publisher Preferred Rates:	-
Test Procedure Version:	2.0.6	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Service Tracking (B15), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	-
Certificate/Result Reviewer:	Herbert Falk	Subscriber Preferred Variants:	
Approval Date:	08/03/2023	Subscriber Preferred Rates:	-
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	TUV SUD China Ltd (A)		
Description			
MiCOM distance protection devices have been designed for the protection of all overhead lines and underground cables where the network is solidly/effectively grounded			

Files

23-D 089191 0043_Schneider_P443_IEC61850Ed2_Server_Certificate.pdf MB 08/03/2023 Herbert Falk