

# IEC 61850 Certificate - IEC 61850 Certificate #6503

## BCU-50-M

08/15/2023 02:26 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	Edition 2 with Amendment 1 Server Test Procedures version 1.1
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	23-2970_DNV_SAE-IT_BCU-50-M_ServerEd2Amd1_Certificate.pdf
<b>61850 Edition:</b>	Edition 2 Amd 1	<b>Certificate Hash:</b>	SHA256: B359336D97EE9E47847FF7E9E4867C B92DE88550F4B5E73090B4961C14EE 15F1
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	SAE IT-Systems GmbH & Co. KG	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	Im Gewerbegebiet Pesch 14 50767 Köln Germany	<b>Umbrella Organization:</b>	
<b>Product:</b>	BCU-50-M	<b>Optional Reservation Test:</b>	Yes
<b>HW Version:</b>		<b>Serial Number:</b>	310050502310
<b>SW Version:</b>	Release 07.003.02B Build 017- 16.05.2023 13:13 Rev 59212	<b>Publisher Legacy Variants:</b>	-
<b>Key Words:</b>	Bay Controller	<b>Publisher Preferred Rates:</b>	-
<b>Test Procedure Version:</b>	1.1	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), SBO Control (12b), Time sync SNTP (B13a), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	-
<b>Certificate/Result Reviewer:</b>	Herbert Falk	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	08/15/2023	<b>Subscriber Preferred Rates:</b>	-
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	DNV Netherlands (A)		
<b>Description</b>			

### Files

23-2970_DNV_SAE-IT_BCU-50-M_ServerEd2Amd1_Certificate.pdf	115 KB	08/15/2023	Herbert Falk
---	--------	------------	--------------