

IEC 61850 Certificate - IEC 61850 Certificate #6504

SBP-K110

08/16/2023 10:50 AM - Herbert Falk

Status:	Approved	Test Document:	Edition 2 Server Test Procedures version 2.0.6
Priority:	Normal	Certificate Name:	23TC200292-R1_Sanion_IED_SBP-K110_Server_Ed2_KERI.pdf
61850 Edition:	Edition 2	Certificate Hash:	SHA256: 2FDFF5D753853A96C82BB26AD07261 D3F96B7C32DE74BB4B86BA8487B682 6F56
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Sanion Co., Ltd.	Vendor Artifact Hash:	
Address:	13, Geomdan-ro, 114-gil, Seo-gu, Incheon, 22663, Republic of Korea	Umbrella Organization:	
Product:	SBP-K110	Optional Reservation Test:	Yes
HW Version:	2.0	Serial Number:	IED-SBP-K110-CU-2023-1001
SW Version:	2.0	Publisher Legacy Variants:	-
Key Words:	Protection, Relay	Publisher Preferred Rates:	-
Test Procedure Version:	2.0.6	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), Service Tracking (B15), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	-
Certificate/Result Reviewer:	Herbert Falk	Subscriber Preferred Variants:	
Approval Date:	08/16/2023	Subscriber Preferred Rates:	-
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Korea Electrotechnology Research Institute (A)		
Description			

History

#1 - 08/16/2023 10:57 AM - Herbert Falk

- *Optional Reservation Test changed from No to Yes*

Files

23TC200292-R1_Sanion_IED_SBP-K110_Server_Ed2_KERI.pdf	506 KB	08/16/2023	Herbert Falk
---	--------	------------	--------------