

IEC 61850 Certificate - IEC 61850 Certificate #6505

ETR500-FV

08/16/2023 10:56 AM - Herbert Falk

Status:	Approved	Test Document:	Edition 2 Server Test Procedures version 2.0.6
Priority:	Normal	Certificate Name:	23TC200623_EntecEnE_IED_ETR500-FV_Server_Ed2_KERI.pdf
61850 Edition:	Edition 2	Certificate Hash:	SHA256: 4888745FA7961CEEED11A3F05BE4D537E8B2F02CF8F138303214641B3268A113
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	ENTEC Electric & Electronic Co., Ltd.	Vendor Artifact Hash:	
Address:	225-38 Choirubaek-ro, Bongdam-eup, Hwasung-city, Gyeonggi-do, 18329, Republic of Korea	Umbrella Organization:	
Product:	ETR500-FV	Optional Reservation Test:	Yes
HW Version:	1.0.2.6	Serial Number:	R22120002
SW Version:	1.0.3.8	Publisher Legacy Variants:	-
Key Words:	Protection, Relay	Publisher Preferred Rates:	-
Test Procedure Version:	2.0.6	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), Service Tracking (B15), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	-
Certificate/Result Reviewer:	Herbert Falk	Subscriber Preferred Variants:	
Approval Date:	08/16/2023	Subscriber Preferred Rates:	-
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Korea Electrotechnology Research Institute (A)		
Description			

Files

23TC200623_EntecEnE_IED_ETR500-FV_Server_Ed2_KERI.pdf	507 KB	08/16/2023	Herbert Falk
---	--------	------------	--------------