

# IEC 61850 Certificate - IEC 61850 Certificate #6506

## SOC-K110

08/16/2023 11:07 AM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	Edition 2 Server Test Procedure version 2.0.6
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	23TC200624_Sanion_IED_SOC-K110_Server_Ed2_KERI.pdf
<b>61850 Edition:</b>	Edition 2	<b>Certificate Hash:</b>	SHA256: 558EC73D7B6FB8E135FDF545D32F60 C97039F62642FE3317A526CAA012D2 3803
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	Sanion Co., Ltd.	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	13, Geomdan-ro, 114-gil, Seo-gu, Incheon, 22663, Republic of Korea	<b>Umbrella Organization:</b>	
<b>Product:</b>	SOC-K110	<b>Optional Reservation Test:</b>	Yes
<b>HW Version:</b>	2.00	<b>Serial Number:</b>	IED-SOC-K110-2023-0001
<b>SW Version:</b>	2.00	<b>Publisher Legacy Variants:</b>	-
<b>Key Words:</b>	Protection, Relay	<b>Publisher Preferred Rates:</b>	-
<b>Test Procedure Version:</b>	2.0.6	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), Service Tracking (B15), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	-
<b>Certificate/Result Reviewer:</b>	Herbert Falk	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	08/16/2023	<b>Subscriber Preferred Rates:</b>	-
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	Korea Electrotechnology Research Institute (A)		
<b>Description</b>			

### History

#1 - 08/23/2023 06:54 AM - Herbert Falk

- 61850 Edition Edition 2 added

- 61850 Edition deleted (Edition 2 Amd 1)

### Files

23TC200624_Sanion_IED_SOC-K110_Server_Ed2_KERI.pdf	507 KB	08/16/2023	Herbert Falk
--	--------	------------	--------------