

## SCL Tooling - Issues #6520

### ICT Ed2.1 refers to TICS but there no part 6 tissues

09/12/2023 09:49 AM - Richard Schimmel

<b>Status:</b> Rejected	<b>Due date:</b> 10/17/2023
<b>Priority:</b> Normal	
<b>Assignee:</b>	
<b>Category:</b>	
<b>Target version:</b>	
<b>Discuss in Upcoming Meeting:</b> No	<b>Updated Test Document:</b>
<b>Clause Reference:</b>	<b>Test Case ID:</b>
<b>61850 Standard:</b> 6	<b>Closed Reason:</b> --Not Set--
<b>Triggering Tissue:</b>	<b>Triggering Tissue 2:</b>
<b>Final Decision:</b>	<b>Triggering Tissue 3:</b>
<b>Initial Test Document:</b> Ed2.1 ICT tool	
<b>Description</b> Ed2.1 ICT test procedures refer to TICS. But the TICS has no part 6 tissues. As such there are no applicable tissues for ICT (and SCT) tool testing. Propose to remove sDoc3 test case and remove TICS reference from certificate template	

#### History

##### #1 - 09/28/2023 08:12 AM - Richard Schimmel

- Status changed from New to In Progress

See draft version 1.1 e-mailed 28 Sept to the TPWG.

##### #2 - 10/03/2023 08:14 AM - IEC 61850 TPWG

- Due date set to 10/17/2023

Can we have an empty TICs?

Presumably we will have a TISSUE on this part at some point. Seems counterproductive to remove.

##### #3 - 10/31/2023 08:35 AM - IEC 61850 TPWG

- Status changed from In Progress to Rejected

As we have a TISSUE (1885) pending, this issue is no longer applicable.