

IEC 61850 Certificate - IEC 61850 Certificate #6521

PGC-6060

09/12/2023 02:33 PM - Herbert Falk

Status:	Approved	Test Document:	Edition 2 Client Conformance Test Procedures version 1.2
Priority:	Normal	Certificate Name:	23-3094_DNV_PSI_ProtocolConverter_ClientEd2_Certificate.pdf
61850 Edition:	Edition 2	Certificate Hash:	SHA256: 7FD00ABCBBB6A6368D0B6D3646DA1 A80578E18ECBBAF67A348CED7B1744 8296C
61850 Tested Aspects:	Client	Vendor Artifact File Name:	
Company:	PSI GridConnect GmbH	Vendor Artifact Hash:	
Address:	Greschbachstrasse 12 76229 Karlsruhe Germany	Umbrella Organization:	
Product:	PGC-6060	Optional Reservation Test:	No
HW Version:		Serial Number:	0005DB81928E
SW Version:	1.0.0 (5) PGC661850	Publisher Legacy Variants:	-
Key Words:	Comm	Publisher Preferred Rates:	-
Test Procedure Version:	1.2	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	-
Certificate/Result Reviewer:	Herbert Falk	Subscriber Preferred Variants:	
Approval Date:	09/12/2023	Subscriber Preferred Rates:	-
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description 61850 Protocol Converter			

Files

23-3094_DNV_PSI_ProtocolConverter_ClientEd2_Certificate.pdf	103 KB	09/12/2023	Herbert Falk
---	--------	------------	--------------