

Harmonizing expressions in 7-500 Ed.1

10/06/2023 08:13 AM - Michael Haecker

Status: New	Start date: 10/06/2023
Priority: Normal	Due date:
Assignee:	% Done: 0%
Category:	
Target version:	
Source:	TF 7-5 Project document: IEC 61850-7-500
Category: Not yet categorized	Related TISSUE:
Description	
In IEC/TR 61850-7-500 Ed.1 the term	
"BIED" (Breaker IED means process near circuit breaker controller same as CBC) is used in a mix with the term	
"CBC" (Process near circuit breaker controller IED according to IEC 62271-3 instead of BIED (breaker IED))	
and the term	
"SIED" (Switch IED means process near disconnector/earthing switch controller same as DCC and/or ESC) is used in a mix with the terms	
"DCC" (Process near disconnector controller IED according to IEC 62271-3 instead of SIED (switch IED)) and	
"ESC" (Process near earthing switch controller IED according to IEC 62271-3 instead of SIED (switch IED)).	
In drawings only one of the parallel terms is used.	
This is to propose to use only one of the parallel terms and to put a general note referring to the other one.	