

IEC 61850 Certificate - IEC 61850 Certificate #6550

VIPAM7000

10/25/2023 09:16 AM - Herbert Falk

Status:	Approved	Test Document:	Edition 2 Server Test Procedures version 2.0.6
Priority:	Normal	Certificate Name:	23TC200842_VitzroEM_IED_VIPAM7000_Server_Ed2_KERI.pdf
61850 Edition:	Edition 2	Certificate Hash:	SHA256: C850E188553A2254E241013F770452E662FB84D22C8FCD8585BAD10D75B913C2
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	VITZRO EM Co., Ltd.	Vendor Artifact Hash:	
Address:	Vitzro Bldg, 7, Neungdong-ro, 25-gil, Gwangjin-gu, Seoul, 22663, Republic of Korea	Umbrella Organization:	
Product:	VIPAM7000	Optional Reservation Test:	Yes
HW Version:	16.00	Serial Number:	2002 3022 1000001
SW Version:	3.0/Firmware: 70.000	Publisher Legacy Variants:	-
Key Words:	Relay	Publisher Preferred Rates:	-
Test Procedure Version:	2.0.6	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), Service Tracking (B15), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	-
Certificate/Result Reviewer:	Herbert Falk	Subscriber Preferred Variants:	
Approval Date:	10/25/2023	Subscriber Preferred Rates:	-
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Korea Electrotechnology Research Institute (A)		
Description			
Protection and Control IED			

Files

23TC200842_VitzroEM_IED_VIPAM7000_Server_Ed2_KERI.pdf	512 KB	10/25/2023	Herbert Falk
---	--------	------------	--------------