

# IEC 61850 Certificate - IEC 61850 Certificate #6552

## P14DZ

10/25/2023 09:42 AM - Herbert Falk

|                                     |  |                                       |   |
|-------------------------------------|--|---------------------------------------|---|
| <b>Status:</b>                      | Approved   | <b>Test Document:</b>                 | Edition 2 Server Procedure version 2.0.6  |
| <b>Priority:</b>                    | Normal   | <b>Certificate Name:</b>              | 23-3120_DNV_GE_Renewable_Energy_P14DZ_ServerEd2_Certificate.pdf                     |
| <b>61850 Edition:</b>               | Edition 2  | <b>Certificate Hash:</b>              | SHA256:<br>20C76AAA2EF8102AB2F7BA1D930205<br>28FEE9CA415E1610E6DF521A8B162A<br>FEB0 |
| <b>61850 Tested Aspects:</b>        | Server   | <b>Vendor Artifact File Name:</b>     |   |
| <b>Company:</b>                     | GE Renewable Energy Ltd.   | <b>Vendor Artifact Hash:</b>          |   |
| <b>Address:</b>                     | St. Leonards Building, Redhill Business Park<br>Stafford, ST16 1WT<br>United Kingdom   | <b>Umbrella Organization:</b>         |   |
| <b>Product:</b>                     | P14DZ  | <b>Optional Reservation Test:</b>     | No  |
| <b>HW Version:</b>                  | E  | <b>Serial Number:</b>                 | 36479124  |
| <b>SW Version:</b>                  | 5  | <b>Publisher Legacy Variants:</b>     | -   |
| <b>Key Words:</b>                   | Relay  | <b>Publisher Preferred Rates:</b>     | -   |
| <b>Test Procedure Version:</b>      | 2.0.6  | <b>Publisher Preferred Variants:</b>  |   |
| <b>IEC 61850 Blocks Certified:</b>  | Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Time Synchronization (B13), Unbuffered Reporting (B5) | <b>Subscriber Legacy Variants:</b>    | -   |
| <b>Certificate/Result Reviewer:</b> | Herbert Falk   | <b>Subscriber Preferred Variants:</b> |   |
| <b>Approval Date:</b>               | 10/25/2023   | <b>Subscriber Preferred Rates:</b>    | -   |
| <b>Standards Tested:</b>            | 61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1   |                                       |   |
| <b>Current Test Lab Name:</b>       | DNV Netherlands (A)  |                                       |   |
| <b>Description</b>                  |  |                                       |   |

### Files

|   |        |            |              |
|---|--------|------------|--------------|
| 23-3120_DNV_GE_Renewable_Energy_P14DZ_ServerEd2_Certificate.pdf | 102 KB | 10/25/2023 | Herbert Falk |
|---|--------|------------|--------------|