

## 61850-7-5 and 61850-7-500 - IEC61850-7-5 #6554

### SwModKey seems to overwrite the CheckCondition.interlockCheck

10/26/2023 02:51 AM - Keith Gray

<b>Status:</b>	Waiting for Release	<b>Start date:</b>	10/26/2023
<b>Priority:</b>	Normal	<b>Due date:</b>	
<b>Assignee:</b>		<b>% Done:</b>	0%
<b>Category:</b>			
<b>Target version:</b>			
<b>Source:</b>		<b>TF 7-5 Project document:</b>	IEC 61850-7-500
<b>Category:</b>	Not yet categorized	<b>Related TISSUE:</b>	<a href="https://iec61850.tissue-db.com/tissue/1845">https://iec61850.tissue-db.com/tissue/1845</a>

#### Description

This was assigned to 7-5/7-500 TF during the 7-5/7-500 meeting in Kista, Sweden on 2023/10/25.

#### History

##### #1 - 01/18/2024 09:05 AM - Thierry Dufaure

Please consider Tissues:

<https://iec61850.tissue-db.com/tissues/1901>

<https://iec61850.tissue-db.com/tissues/1845>

<https://iec61850.tissue-db.com/tissues/1782>

##### #2 - 01/18/2024 09:35 AM - Michael Haecker

Decision of the TF (2024-01-18):

The clause about SwModKey which was revised during the meeting shall find its place in TR 7-500. It is posted on the IEC Collaboration Tool

<https://collaborate.iec.ch/#/pages/workspaces/137208/documents/201792/details/826219?onlyWithPreview=false&fileId=826219>.

The resolution of Tissue 1845 <https://iec61850.tissue-db.com/tissues/1845> can made use of that text.

Table 1 of IEC/TR 61850-7-5 shall be deleted, as its content contradicts to IEC 61850-7-2 and to the content of the new table (Tissue 1901

<https://iec61850.tissue-db.com/tissues/1901>).

##### #3 - 02/29/2024 07:16 AM - Keith Gray

I have integrated the text from Michael into the document in preparation for the 2024/02/29 TF meeting.

##### #4 - 02/29/2024 07:19 AM - Keith Gray

- Status changed from New to In Progress

##### #5 - 02/29/2024 07:52 AM - Keith Gray

- Status changed from In Progress to Waiting for Release

- TF 7-5 Project document IEC 61850-7-500 added

- TF 7-5 Project document deleted (-)

Reviewed during the TF meeting on 2024/02/29.