

Server - Issues #6565

Added more precise qualifications to TmSrcTyp - 1883

10/31/2023 07:42 AM - IEC 61850 TPWG

Status: Rejected	Due date: 11/14/2023
Priority: Normal	
Assignee: Richard Schimmel	
Category:	
Target version:	
Discuss in Upcoming Meeting: No	Updated Test Document:
Clause Reference:	Test Case ID: sTm5, sTmP5
61850 Standard: 7-4	Closed Reason: No Action Taken
Triggering Tissue: https://iec61850.tissue-db.com/tissue/1883	Triggering Tissue 2:
Final Decision:	Triggering Tissue 3:
Initial Test Document: Ed2.1 TP1.2	
Description	

History

#1 - 10/31/2023 08:40 AM - IEC 61850 TPWG

- Due date changed from 11/07/2023 to 11/14/2023
- Status changed from New to In Progress

#2 - 10/31/2023 08:53 AM - IEC 61850 TPWG

- Assignee set to Richard Schimmel

#3 - 11/14/2023 06:50 AM - Richard Schimmel

- Subject changed from Added more precise qualifications to TmSrcTyp - 1883 to Added more precise qualifications to TmSrcTyp - 1883
- Initial Test Document set to Ed2.1 TP1.2
- Test Case ID set to sTm5, sTmP5

sTm5 validates LTMS.TmSrcTyp=SNTP, sTmP5 validates LTMS.TmSrcTyp=PTP. When the clocksource is unavailable the applicable TmChStX changes from True to False. Is this sufficient?

#4 - 11/14/2023 09:02 AM - IEC 61850 TPWG

- Closed Reason No Action Taken added
- Closed Reason deleted (--Not Set--)

No change in test procedure.

#5 - 11/14/2023 09:03 AM - IEC 61850 TPWG

- Status changed from In Progress to Rejected