

IEC 61850 Certificate - IEC 61850 Certificate #6585

DW-SPiN-LID

11/08/2023 08:32 AM - Herbert Falk

Status:	Approved	Test Document:	Edition 2 Server Test Procedures version 2.0.6
Priority:	Normal	Certificate Name:	23TC200880_DAEWOONG_SA-LID_DW-SPiN-LID_Server_Ed2_KERI.pdf
61850 Edition:	Edition 2	Certificate Hash:	SHA256: 7F7A3CF589AF06C6A9C45934E2E2D0 2383B04C1A08BC49343647071325F7E BD1
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	DAEWOONG ELECTRIC Co., Ltd.	Vendor Artifact Hash:	
Address:	Hwanggeumro 127beon-gil 10, Yangchon-eup, Gimpo-si, Gyeonggi-do, 10048, Republic of Korea	Umbrella Organization:	
Product:	DW-SPiN-LID	Optional Reservation Test:	Yes
HW Version:	1.0.0.0	Serial Number:	DWE-SNLI2301
SW Version:	1.0.0.0	Publisher Legacy Variants:	-
Key Words:	Bay Controller, RTU	Publisher Preferred Rates:	-
Test Procedure Version:	2.0.6	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), Service Tracking (B15), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	-
Certificate/Result Reviewer:	Herbert Falk	Subscriber Preferred Variants:	
Approval Date:	11/08/2023	Subscriber Preferred Rates:	-
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Korea Electrotechnology Research Institute (A)		
Description			
SA-LID (Substation Automation Local Information Processing Device)			

Files

23TC200880_DAEWOONG_SA-LID_DW-SPiN-LID_Server_Ed2_KERI.pdf	507 KB	11/08/2023	Herbert Falk
--	--------	------------	--------------