

# IEC 61850 Certificate - IEC 61850 Certificate #6586

## HP-Z8-G4

11/08/2023 07:00 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	Edition 2 Client Test Procedures version 1.2
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	23-039348-02-2_YouSung_HP-Z8-G4_Client_Ed2_Certificate_KTL.pdf
<b>61850 Edition:</b>	Edition 2	<b>Certificate Hash:</b>	SHA256: F811DA685033491150C8057667A94AC C2F9DC165C0D04D239D30BDB82B06 065F
<b>61850 Tested Aspects:</b>	Client	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	YouSung Instrument & Electric Co., Ltd.	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	37, Namdongdong-ro 64beon-gil, Namdong-gu, Incheon, Republic of Korea, 21692	<b>Umbrella Organization:</b>	
<b>Product:</b>	HP-Z8-G4	<b>Optional Reservation Test:</b>	Yes
<b>HW Version:</b>	1	<b>Serial Number:</b>	4CE226CB60
<b>SW Version:</b>	2	<b>Publisher Legacy Variants:</b>	-
<b>Key Words:</b>		<b>Publisher Preferred Rates:</b>	-
<b>Test Procedure Version:</b>	1.2	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Control Block (9), SBO Control (12b), Service Tracking (B15), Setting Group (B4), Setting Group Definition (B4+), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	-
<b>Certificate/Result Reviewer:</b>	Herbert Falk	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	11/08/2023	<b>Subscriber Preferred Rates:</b>	-
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	Korea Testing Laboratory (A)		
<b>Description</b>			
SA-OPD (Substation Automation Operation Processing Device)			

### History

#1 - 11/08/2023 07:07 PM - Herbert Falk

- Standards Tested 61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4 added

### Files

23-039348-02-2\_YouSung\_HP-Z8-G4\_Client\_Ed2\_Certificate\_KTL.pdf 89 KB

11/09/2023

Herbert Falk