

# IEC 61850 Certificate - IEC 61850 Certificate #6593

## YH-HSA-LID

11/09/2023 07:16 AM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	Edition 2 Server Test Procedures version 2.0.6
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	23-029995-02-1_YouHo_SALID_Server_Ed2_Certification_KTL.pdf
<b>61850 Edition:</b>	Edition 2	<b>Certificate Hash:</b>	SHA256: 4A4B46362E9B66940D8895EFA5EB07 950768098A44DD800F0C4803C89A01 EEE2
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	YOUHO Electric Ind CO., Ltd.	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	39-42, 1253 BEON-GIL, GWONYUL-RO, BAEKSEOK-EUP, YANGJU-SI, GYEONGGI-DO, Republic of Korea	<b>Umbrella Organization:</b>	
<b>Product:</b>	YH-HSA-LID	<b>Optional Reservation Test:</b>	Yes
<b>HW Version:</b>	1	<b>Serial Number:</b>	YH-HSA-LID-23001
<b>SW Version:</b>	2.0.0.4	<b>Publisher Legacy Variants:</b>	-
<b>Key Words:</b>		<b>Publisher Preferred Rates:</b>	-
<b>Test Procedure Version:</b>	2.0.6	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), Service Tracking (B15), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	-
<b>Certificate/Result Reviewer:</b>	Herbert Falk	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	11/09/2023	<b>Subscriber Preferred Rates:</b>	-
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	Korea Testing Laboratory (A)		
<b>Description</b>			
SA-LID			

### Files

23-029995-02-1_YouHo_SALID_Server_Ed2_Certification_KTL.pdf	124 KB	11/09/2023	Herbert Falk
---	--------	------------	--------------