

IEC 61850 Certificate - IEC 61850 Certificate #6603

BCU 500

11/19/2023 08:51 AM - Herbert Falk

Status:	Approved	Test Document:	Edition 2 with Amendment 1 Server Test Procedure 1.2
Priority:	Normal	Certificate Name:	23-3220_DNV_Efacec_BCU500_TPU500_ServerEd2Amd1_Certificate.pdf
61850 Edition:	Edition 2 Amd 1	Certificate Hash:	23-3220_DNV_Efacec_BCU500_TPU500_ServerEd2Amd1_Certificate.pdf
61850 Tested Aspects:	Sampled Values, Server	Vendor Artifact File Name:	
Company:	"Efacec Energia Máquinas e Equipamentos Eléctricos, S.A."	Vendor Artifact Hash:	
Address:	Via de Francisco Sá Carneiro 4471-907 Moreira da Maia Portugal	Umbrella Organization:	
Product:	BCU 500	Optional Reservation Test:	Yes
HW Version:	BCU 500-3-1-B-2-C-B-B-E-X-X-X-X-X-X-X-X-O-1-X-X-X-XXXX-8-1-CXXX-A2B1	Serial Number:	954525
SW Version:	5.06.001	Publisher Legacy Variants:	-
Key Words:		Publisher Preferred Rates:	-
Test Procedure Version:	1.2	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Basic Exchange (B1a), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Sampled Value Subscribe (11b), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time Synchronization (B13), Time sync PTP (B13b), Time sync SNTP (B13a), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	-, F4000S114U4
Certificate/Result Reviewer:	Herbert Falk	Subscriber Preferred Variants:	F4800S2I8U8
Approval Date:	11/19/2023	Subscriber Preferred Rates:	F4800S2
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			
Bay Controller			

History

#1 - 11/19/2023 09:06 AM - Herbert Falk

- File 23-3220_DNV_Efacec_BCU500_TPU500_ServerEd2Amd1_Certificate.pdf added

#2 - 11/19/2023 09:06 AM - Herbert Falk

- File deleted (23-3220_DNV_Efacec_BCU500_TPU500_ServerEd2Amd1_Certificate.pdf)

#3 - 02/05/2024 08:53 AM - Herbert Falk

- 61850 Tested Aspects Sampled Values added

Files

23-3220_DNV_Efacec_BCU500_TPU500_ServerEd2Amd1_Certificate.pdf	20 KB	11/19/2023	Herbert Falk
--	-------	------------	--------------