

61850-7-5 and 61850-7-500 - IEC61850-7-5 #6607

Create DO indicating the source of synchronisation

11/21/2023 08:49 AM - Vladan Cvejic

Status:	New	Start date:	05/17/2021
Priority:	Normal	Due date:	10/17/2021
Assignee:		% Done:	0%
Category:			
Target version:			
Source:	RTE	TF 7-5 Project document:	-
Category:	Not yet categorized	Related TISSUE:	
Description			
Proposal to add in LTMS a DO indicating the current source of synchronisation of the IED. This should be done in a consistent way with SynSrcId added in the SV ADSU in 9-2 ed2.1. Proposal: add new DO (> 64 bit) to LTMS and MMXU.			
Related issues:			
Copied from IEC 61850 User Feedback Task Force - Improvement #672: Create DO ...		Resolved	05/17/2021 10/17/2021

History

#1 - 11/21/2023 08:49 AM - Vladan Cvejic

- Copied from Improvement #672: Create DO indicating the source of synchronisation added