

# IEC 61850 Certificate - IEC 61850 Certificate #6623

CPD0100

12/09/2023 10:23 AM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	Edition 2 Server Test Procedures version 2.0.6
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	HangZhou Deruida Electric Co., Ltd._ CPD100_ DC Traction Power Systems Control and Protection Relays_2023PUCA000001_KETOP.pdf
<b>61850 Edition:</b>	Edition 2	<b>Certificate Hash:</b>	SHA256: BD827F209749813BFCC6B8B1AA31A5 EB924E64B81CE25B5773A1F264F34E 630A
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	HangZhou Deruida Electric Co., Ltd.	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	Room 214, floor 2, building 1, No.11, Liangzhan Road, Renhe street, Yuhang District, Hangzhou City, Zhejiang Province, China	<b>Umbrella Organization:</b>	
<b>Product:</b>	DC Traction Power Systems Control and Protection Relays	<b>Optional Reservation Test:</b>	Yes
<b>HW Version:</b>	V1.00	<b>Serial Number:</b>	
<b>SW Version:</b>	1020 0001	<b>Publisher Legacy Variants:</b>	-
<b>Key Words:</b>	Relay	<b>Publisher Preferred Rates:</b>	-
<b>Test Procedure Version:</b>	2.0.6	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	-
<b>Certificate/Result Reviewer:</b>	Herbert Falk	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	12/09/2023	<b>Subscriber Preferred Rates:</b>	-
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	Xuchang KETOP Testing Research Institute Co.(A)		
<b>Description</b>			
DC Traction Power Systems Control and Protection Relays			

## History

#1 - 12/09/2023 10:28 AM - Herbert Falk

- Current Test Lab Name changed from Korea Testing Laboratory (A) to Xuchang KETOP Testing Research Institute Co.(A)

#2 - 12/09/2023 10:34 AM - Herbert Falk

- Subject changed from DC Traction Power Systems Control and Protection Relays to CPD100

- Description updated

**#3 - 12/09/2023 11:01 AM - Herbert Falk**

- Optional Reservation Test changed from No to Yes

**#4 - 12/09/2023 11:03 AM - Herbert Falk**

- Subject changed from CPD100 to CPD0100

**Files**

---

HangZhou Deruida Electric Co., Ltd.\_ CPD100\_ DC Traction Power System Control and Protection Relays\_2023PUCA000001\_KETOP.pdf Herbert Falk