

IEC 61850 Certificate - IEC 61850 Certificate #6625

CSC-281 Multifunction Feeder Protection LED

12/09/2023 11:01 AM - Herbert Falk

Status:	Approved	Test Document:	Edition 2 Server Test Procedures version 2.0.6
Priority:	Normal	Certificate Name:	BEIJING SIFANG AUTOMATION CO., LTD. BEIJING SIFANG ENGINEERING CO., LTD._ CSC-281_ Multifunction Feeder Protection LED_2023PUCA000005_KETOP.pdf
61850 Edition:	Edition 2	Certificate Hash:	SHA256: 24650ECFAB95EC9E3FE84E498B9649 BB010BA59A9BE724F3F29BE58E51A5 D65E
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	BEIJING SIFANG AUTOMATION CO.,LTD	Vendor Artifact Hash:	
Address:	Number9, Shangdi 4th Street, Haidian District, Beijing, P.R.C.100085	Umbrella Organization:	
Product:	CSC-281	Optional Reservation Test:	Yes
HW Version:		Serial Number:	
SW Version:	V1.0	Publisher Legacy Variants:	-
Key Words:	Relay	Publisher Preferred Rates:	-
Test Procedure Version:	2.0.6	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Enhanced SBO Control (12d), File Transfer (B14), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	-
Certificate/Result Reviewer:	Herbert Falk	Subscriber Preferred Variants:	
Approval Date:	12/09/2023	Subscriber Preferred Rates:	-
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Xuchang KETOP Testing Research Institute Co.(A)		

Description

The CSC-281 is applicable to the power distribution system of 35kV or the below voltage in power, petrochemistry, iron and steel, metallurgy and other industries.

History

#1 - 12/09/2023 11:10 AM - Herbert Falk

- 61850 Edition Edition 2 added

- 61850 Edition deleted (Edition 2 Amd 1)

Files

BEIJING SIFANG AUTOMATION CO., LTD. BEIJING SIFANG ENGINEERING CO., LTD._ CSC-281_ Multifunction Feeder Protection LED_2023PUCA000005_KETOP.pdf