

# IEC 61850 Certificate - IEC 61850 Certificate #6626

## CSC-283 - Motor Protection IED

12/09/2023 11:07 AM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	Edition 2 Server Test Procedures version 2.0.6
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	BEIJING SIFANG AUTOMATION CO., LTD. BEIJING SIFANG ENGINEERING CO., LTD._ CSC-283_ Motor Protection LED_2023PUCA000006_KETOP.pdf
<b>61850 Edition:</b>	Edition 2	<b>Certificate Hash:</b>	SHA256: 8C38B77F15886D47CF7A0EA02AD779 C15B2517199BB86379BBDC1F409C3B FAA2
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	BEIJING SIFANG AUTOMATION CO.,LTD	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	Number9, Shangdi 4th Street, Haidian District, Beijing, P.R.C.100085	<b>Umbrella Organization:</b>	
<b>Product:</b>	CSC-283 - Motor Protection IED	<b>Optional Reservation Test:</b>	Yes
<b>HW Version:</b>		<b>Serial Number:</b>	
<b>SW Version:</b>	V1.0	<b>Publisher Legacy Variants:</b>	-
<b>Key Words:</b>	Relay	<b>Publisher Preferred Rates:</b>	-
<b>Test Procedure Version:</b>	2.0.6	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Enhanced SBO Control (12d), File Transfer (B14), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	-
<b>Certificate/Result Reviewer:</b>	Herbert Falk	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	12/09/2023	<b>Subscriber Preferred Rates:</b>	-
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	Xuchang KETOP Testing Research Institute Co.(A)		
<b>Description</b>			
The CSC-283 is applicable to the power distribution system of 35kV or the below voltage in power, petrochemistry, iron and steel, metallurgy and other industries.			

### History

#1 - 12/09/2023 11:09 AM - Herbert Falk

- Optional Reservation Test changed from No to Yes

#2 - 12/09/2023 11:10 AM - Herbert Falk

- 61850 Edition Edition 2 added

- 61850 Edition deleted (Edition 2 Amd 1)

**#3 - 01/08/2024 08:34 AM - Herbert Falk**

- File BEIJING SIFANG AUTOMATION CO., LTD. BEIJING SIFANG ENGINEERING CO., LTD.\_ CSC-283\_ Motor Protection LED\_2023PUCA000006\_KETOP.pdf added

- Certificate Name changed from BEIJING SIFANG AUTOMATION CO., LTD. BEIJING SIFANG ENGINEERING CO., LTD.\_ CSC-283\_ Motor Protection LED\_2023PUCA000006\_KETOP .pdf to BEIJING SIFANG AUTOMATION CO., LTD. BEIJING SIFANG ENGINEERING CO., LTD.\_ CSC-283\_ Motor Protection LED\_2023PUCA000006\_KETOP.pdf

- Certificate Hash changed from SHA256: 4F873FDBA5013CAD992D7C9A5231A25444D04F8C890F23997323545E1FB4EC72 to SHA256: 8C38B77F15886D47CF7A0EA02AD779C15B2517199BB86379BBDC1F409C3BFAA2

**#4 - 01/08/2024 08:34 AM - Herbert Falk**

- File deleted (BEIJING SIFANG AUTOMATION CO., LTD. BEIJING SIFANG ENGINEERING CO., LTD.\_ CSC-283\_ Motor Protection LED\_2023PUCA000006\_KETOP .pdf)

**Files**

---

BEIJING SIFANG AUTOMATION CO., LTD. BEIJING SIFANG ENGINEERING CO., LTD.\_ CSC-283\_ Motor Protection LED\_2023PUCA000006\_KETOP.pdf