

IEC 61850 Certificate - IEC 61850 Certificate #6629

T-MU MERGING UNIT - IED

12/09/2023 11:47 AM - Herbert Falk

Status:	Approved	Test Document:	Edition 2 with Amendment 1 Server Test Procedures version 1.2
Priority:	Normal	Certificate Name:	23-074632-01-1_KMData_T-MU_Server_Ed2.1_Certification_KTL_ver1.0.pdf
61850 Edition:	Edition 2 Amd 1	Certificate Hash:	SHA256: 34424F7033DD23C1AF74DE1158DA56 23C6C18C50A4079E947DA2554D033A 0E8D
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	KMDATA INC.	Vendor Artifact Hash:	
Address:	505-2, Daeryung Techno Town 1-cha, Gasan Digital 2-ro 18, Geumcheon-gu, Seoul, Republic of Korea	Umbrella Organization:	
Product:	T-MU	Optional Reservation Test:	No
HW Version:	1.0.0	Serial Number:	KMDMU23-60-2310001
SW Version:	2.1.0	Publisher Legacy Variants:	F12800S8I4U4, F15360S8I4U4, F4000S1I4U4, F4800S1I4U4
Key Words:		Publisher Preferred Rates:	-, F14400S6, F4800S2
Test Procedure Version:	1.2	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Sampled Value Publish (11a)	Subscriber Legacy Variants:	-
Certificate/Result Reviewer:	Herbert Falk	Subscriber Preferred Variants:	
Approval Date:	12/09/2023	Subscriber Preferred Rates:	-
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1, 61869-9		
Current Test Lab Name:	Korea Testing Laboratory (A)		
Description			
MERGING UNIT - IED			

Files

23-074632-01-1_KMData_T-MU_Server_Ed2.1_Certification_KTL_ver1.0.pdf	1.61 MB	12/09/2023	Herbert Falk
--	---------	------------	--------------