

IEC 61850 Certificate - IEC 61850 Certificate #6637

PCM600

12/13/2023 07:31 AM - Herbert Falk

Status:	Approved	Test Document:	Edition 2 with Admendent 1 Test Procedures for Server IED Configuration Tool (ICT) version 1.1
Priority:	Normal	Certificate Name:	23-3144_DNV_Hitachi_PCM600_ICTed2 Amd1_Certificate TP1p1.pdf
61850 Edition:	Edition 2 Amd 1	Certificate Hash:	SHA256: 74D26989D30CA160BA3B7F4E3BA025 2EB705EE0FBD283A2D006E1450173B 6906
61850 Tested Aspects:	SCL-ICT	Vendor Artifact File Name:	
Company:	Hitachi Energy Sweden AB	Vendor Artifact Hash:	
Address:	GA Products SE-721 59 Västerås Sweden	Umbrella Organization:	
Product:	PCM600	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	Version: 3.0 with Hotfix 2	Publisher Legacy Variants:	-
Key Words:	ICT	Publisher Preferred Rates:	-
Test Procedure Version:	1.1	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	(ICT-21) ICD Export, (ICT-22) SCD Import, (ICT-23) IID Export, (ICT-24) ICT Tool Functionality, Basic Exchange (B1)	Subscriber Legacy Variants:	-
Certificate/Result Reviewer:	Herbert Falk	Subscriber Preferred Variants:	
Approval Date:	12/13/2023	Subscriber Preferred Rates:	-
Standards Tested:	61850-6		
Current Test Lab Name:	DNV Netherlands (A)		
Description			
ICT, Tested with REC670 software version 2.2.19.1			

History

#1 - 12/13/2023 07:32 AM - Herbert Falk

- Key Words ICT added

#2 - 01/21/2024 10:43 AM - Herbert Falk

- File deleted (23-3144_DNV_Hitachi_PCM600_ICTed2Amd1_Certificate TP1p1.pdf)

#3 - 01/21/2024 10:44 AM - Herbert Falk

- File 23-3144_Rev1_DNV_Hitachi_PCM600_ICTed2Amd1_Certificate.pdf added

- Address updated

Files

