

IEC 61850 Certificate - IEC 61850 Certificate #6638

HP-Z8-G4

12/13/2023 07:48 AM - Herbert Falk

Status:	Approved	Test Document:	Edition 2 Client Test Procedures version 1.2
Priority:	Normal	Certificate Name:	23-039473-02-2_Daonsys_HP-Z8-G4_Client_Ed2_Certification_KTL.pdf
61850 Edition:	Edition 2	Certificate Hash:	SHA256: B4A36883D782F1BE5D54C14D7B1EE6 103F46022895C4C0F0027AEC0D0EB1 A41B
61850 Tested Aspects:	Client	Vendor Artifact File Name:	
Company:	DAONSY Co., Ltd.	Vendor Artifact Hash:	
Address:	"70, Aenggogae-ro 556beon-gil, Namdong-gu, Incheon, Republic of Korea, 21692"	Umbrella Organization:	
Product:	HP-Z8-G4	Optional Reservation Test:	Yes
HW Version:	1	Serial Number:	
SW Version:	2	Publisher Legacy Variants:	-
Key Words:		Publisher Preferred Rates:	-
Test Procedure Version:	1.2	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Control Block (9), SBO Control (12b), Service Tracking (B15), Setting Group (B4), Setting Group Definition (B4+), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	-
Certificate/Result Reviewer:	Herbert Falk	Subscriber Preferred Variants:	
Approval Date:	12/13/2023	Subscriber Preferred Rates:	-
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Korea Testing Laboratory (A)		
Description			
SA-OPD (Substation Automation Operation Processing Device)			

Files

23-039473-02-2_Daonsys_HP-Z8-G4_Client_Ed2_Certification_KTL.pdf	66.4 KB	12/13/2023	Herbert Falk
--	---------	------------	--------------