

IEC 61850 Certificate - IEC 61850 Certificate #6639

ECU-4784

12/13/2023 07:55 AM - Herbert Falk

Status:	Approved	Test Document:	Edition 2 Client Test Procedures version 1.2
Priority:	Normal	Certificate Name:	23-039475-02-2_Daonsys_ECU-4784_Client_Ed2_Certification_KTL.pdf
61850 Edition:	Edition 2	Certificate Hash:	SHA256: A4D1EC7BDC58062B20CF732DF80E0 0F014041503EABDD7ED9DB16E11CE 83FF27
61850 Tested Aspects:	Client	Vendor Artifact File Name:	
Company:	DAONSY Co., Ltd.	Vendor Artifact Hash:	
Address:	"70, Aenggogae-ro 556beon-gil, Namdong-gu, Incheon, Republic of Korea, 21692"	Umbrella Organization:	
Product:	ECU-4784	Optional Reservation Test:	No
HW Version:	1	Serial Number:	KMA7946325
SW Version:	2 OS : Windows Server 2019	Publisher Legacy Variants:	-
Key Words:		Publisher Preferred Rates:	-
Test Procedure Version:	1.2	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Control Block (9), SBO Control (12b), Service Tracking (B15), Setting Group (B4), Setting Group Definition (B4+), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	-
Certificate/Result Reviewer:	Herbert Falk	Subscriber Preferred Variants:	
Approval Date:	12/13/2023	Subscriber Preferred Rates:	-
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Korea Testing Laboratory (A)		
Description			
SA ICD (Substation Automation Information Connecting Device)			

Files

23-039475-02-2_Daonsys_ECU-4784_Client_Ed2_Certification_KTL.pdf 20 KB

12/13/2023

Herbert Falk