

IEC 61850 Certificate - IEC 61850 Certificate #6640

ECU-4784

12/13/2023 07:59 AM - Herbert Falk

Status:	Approved	Test Document:	Edition 2 Server Test Procedures version 2.0.6
Priority:	Normal	Certificate Name:	23-039475-02-3_Daonsys_ECU-4784_Server_Ed2_Certification_KTL.pdf
61850 Edition:	Edition 2	Certificate Hash:	SHA256: 98AB349E81B445A78C6EF8AD6C8EC 8083831ACD91DC5802FF60DDD00F68 B4843
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	DAONSY Co., Ltd.	Vendor Artifact Hash:	
Address:	"70, Aenggogae-ro 556beon-gil, Namdong-gu, Incheon, Republic of Korea, 21692"	Umbrella Organization:	
Product:	ECU-4784	Optional Reservation Test:	Yes
HW Version:	1	Serial Number:	KMA7946325
SW Version:	2	Publisher Legacy Variants:	-
Key Words:		Publisher Preferred Rates:	-
Test Procedure Version:	2.0.6	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), File Transfer (B14), Service Tracking (B15), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	-
Certificate/Result Reviewer:	Herbert Falk	Subscriber Preferred Variants:	
Approval Date:	12/13/2023	Subscriber Preferred Rates:	-
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Korea Testing Laboratory (A)		
Description			
SA ICD (Substation Automation Information Connecting Device)			

Files

23-039475-02-3_Daonsys_ECU-4784_Server_Ed2_Certification_KTL.pdf 5 KB 12/13/2023 Herbert Falk