

# IEC 61850 Certificate - IEC 61850 Certificate #6641

## Arkens PR Line L301

12/13/2023 08:26 AM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	Edition 2 with Amendment 1 Server Test Procedures version 1.2
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	23-3274_DNV_SCLE_ARKENSPR_LINE-L301_ServerEd2Amd1_Certificate.pdf
<b>61850 Edition:</b>	Edition 2 Amd 1	<b>Certificate Hash:</b>	SHA256: 286346E3796BEC939BD7E8578B17D9 FF911565347EE1D53A40EFEC365169 C38F
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	SCLE SFE	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	25 chemin de Paléficat, 31200 Toulouse France	<b>Umbrella Organization:</b>	
<b>Product:</b>	Arkens PR Line L301	<b>Optional Reservation Test:</b>	Yes
<b>HW Version:</b>		<b>Serial Number:</b>	20.26.025.D
<b>SW Version:</b>	"Firmware version 2.1a revision 461668 Package version 1.00.1.0 revision 461393"	<b>Publisher Legacy Variants:</b>	-
<b>Key Words:</b>		<b>Publisher Preferred Rates:</b>	-
<b>Test Procedure Version:</b>	1.2	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1a), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Substitution (B3), Time sync SNTP (B13a), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	-
<b>Certificate/Result Reviewer:</b>	Herbert Falk	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	12/13/2023	<b>Subscriber Preferred Rates:</b>	-
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	DNV Netherlands (A)		
<b>Description</b>			

### Files

23-3274_DNV_SCLE_ARKENSPR_LINE-L301_ServerEd2Amd1_Certificate.pdf	12/13/2023	Herbert Falk
---	------------	--------------