

IEC 61850 Certificate - IEC 61850 Certificate #6642

AXC F 3152

12/13/2023 08:37 AM - Herbert Falk

Status:	Approved	
Priority:	Normal	
61850 Edition:	Edition 2 Amd 1	Certificate Name: 23-3267_DNV_Phoenix_Contact_AXC_F_3152_ServerEd2Amd1_Certificate.pdf
61850 Tested Aspects:	Server	Certificate Hash: SHA256: 0069EA341DF72621489C50CBC3A979 4D45B12A80D993E521F0E63BFF0170 638C
Company:	PHOENIX CONTACT GmbH & Co. KG	Vendor Artifact File Name:
Address:	Flachsmarktstraße 8 32825 Blomberg Germany	Vendor Artifact Hash:
Product:	AXC F 3152	Umbrella Organization:
HW Version:		Optional Reservation Test: No
SW Version:	PLCnext IEC 61850 v1.1.0	Serial Number:
Key Words:		Publisher Legacy Variants: -
Test Procedure Version:	1.2	Publisher Preferred Rates: -
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), SBO Control (12b), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time sync SNTP (B13a), Unbuffered Reporting (B5)	Publisher Preferred Variants:
Certificate/Result Reviewer:	Herbert Falk	Subscriber Legacy Variants: -
Approval Date:	12/13/2023	Subscriber Preferred Variants:
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Subscriber Preferred Rates: -
Current Test Lab Name:	DNV Netherlands (A)	Product Variants:
Test Document:	Edition 2 with Amendment 1 Server Test Procedures version 1.2	Time Activated Control:
Description PLCnext Control		

Files

23-3267_DNV_Phoenix_Contact_AXC_F_3152_ServerEd2Amd1_Certificate.pdf	12/13/2023	Herbert Falk
--	------------	--------------