

IEC 61850 Certificate - IEC 61850 Certificate #6643

AXC F 2152

12/13/2023 08:42 AM - Herbert Falk

Status:	Approved	Test Document:	Edition 2 with Amendment 1 Server Test Procedures version 1.2
Priority:	Normal	Certificate Name:	23-3288_DNV_Phoenix_Contact_AXC_F_2152_ServerEd2Amd1_Certificate.pdf
61850 Edition:	Edition 2 Amd 1	Certificate Hash:	SHA256: 924B3727C230B6287021B3253EBB6D E8EA79AF82189B1BCCA0438BB0B5B F3130
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	PHOENIX CONTACT GmbH & Co. KG	Vendor Artifact Hash:	
Address:	Flachsmarktstraße 8 32825 Blomberg Germany	Umbrella Organization:	
Product:	AXC F 2152	Optional Reservation Test:	No
HW Version:	06	Serial Number:	
SW Version:	PLCnext IEC 61850 v1.1.0	Publisher Legacy Variants:	-
Key Words:		Publisher Preferred Rates:	-
Test Procedure Version:	1.2	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1a), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), SBO Control (12b), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time sync SNTP (B13a), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	-
Certificate/Result Reviewer:	Herbert Falk	Subscriber Preferred Variants:	
Approval Date:	12/13/2023	Subscriber Preferred Rates:	-
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			
PLCnext Control			

Files

23-3288_DNV_Phoenix_Contact_AXC_F_2152_ServerEd2Amd1_Certificate.pdf	12/13/2023	Herbert Falk
--	------------	--------------