

IEC 61850 Certificate - IEC 61850 Certificate #6645

F8300

12/16/2023 09:21 AM - Herbert Falk

Status:	Approved	Test Document:	Edition 2 with Amendment 1 Server Test Procedures version 1.2
Priority:	Normal	Certificate Name:	23-3236_DNV_Doble_F8300_F8200_ServerEd2Amd1_Certificate.pdf
61850 Edition:	Edition 2 Amd 1	Certificate Hash:	SHA256: 91262A7BD376EF57E127CFB51E0E6D 8A173EF36DDEB4F0F9F7C5BE54F4C 6CE67
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Doble Engineering Company	Vendor Artifact Hash:	
Address:	123 Felton Street Marlborough, MA 01752 USA	Umbrella Organization:	
Product:	F8300	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	1.1.2.1546	Publisher Legacy Variants:	F4000S1I4U4, F4800S1I4U4
Key Words:		Publisher Preferred Rates:	F4800S2
Test Procedure Version:	1.2	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), GOOSE Publish (9a), GOOSE Subscribe (9b), Sampled Value Publish (11a), Time sync PTP (B13b), Time sync SNTP (B13a)	Subscriber Legacy Variants:	-
Certificate/Result Reviewer:	Herbert Falk	Subscriber Preferred Variants:	
Approval Date:	12/16/2023	Subscriber Preferred Rates:	-
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1, 61869-9		
Current Test Lab Name:	DNV Netherlands (A)		
Description			
Power System Simulator			

Files

23-3236_DNV_Doble_F8300_F8200_ServerEd2Amd1_Certificate.pdf 100 KB

12/16/2023

Herbert Falk