

# IEC 61850 Certificate - IEC 61850 Certificate #6646

## SPiN-IMCU

12/16/2023 09:27 AM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	Edition 2 Server Test Procedures version 2.0.6
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	23TC200993_DAEWOONG_IED_SPiN-IMCU_Server_Ed2_KERI.pdf
<b>61850 Edition:</b>	Edition 2	<b>Certificate Hash:</b>	SHA256: E51526991A0AECD290F83EC37F1FC6 E2606C279935929B05454B4066912BA FCB
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	DAEWOONG ELECTRIC Co., Ltd.	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	Hwanggeumro 127beon-gil 10, Yangchon-eup, Gimpo-si, Gyeonggi-do, 10048, Republic of Korea	<b>Umbrella Organization:</b>	
<b>Product:</b>	SPiN-IMCU	<b>Optional Reservation Test:</b>	No
<b>HW Version:</b>	1.00	<b>Serial Number:</b>	DWE-SNIMCU2301
<b>SW Version:</b>	2.00	<b>Publisher Legacy Variants:</b>	-
<b>Key Words:</b>		<b>Publisher Preferred Rates:</b>	-
<b>Test Procedure Version:</b>	2.0.6	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), Service Tracking (B15), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	-
<b>Certificate/Result Reviewer:</b>	HerbertFalk	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	12/16/2023	<b>Subscriber Preferred Rates:</b>	-
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	Korea Electrotechnology Research Institute (A)		
<b>Description</b>			

### History

#1 - 12/16/2023 09:27 AM - Herbert Falk

- Address updated

### Files

23TC200993\_DAEWOONG\_IED\_SPiN-IMCU\_Server\_Ed2\_KERI.pdf 507 KB

12/16/2023

Herbert Falk