

IEC 61850 Certificate - IEC 61850 Certificate #6649

HGMAP-BCS

12/16/2023 10:44 AM - Herbert Falk

Status:	Approved	Test Document:	Edition 2 Server Test Procedure version 2.0.6
Priority:	Normal	Certificate Name:	23-063447-01-1__HD Electric_HGMAP-BCS_Server_Ed2_Certification_KTL.pdf
61850 Edition:	Edition 2	Certificate Hash:	SHA256: BE22CA352AC614B93C676F056EE298 94143000695C71EBD3B589BED89CB6 655A
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	HD Hyundai Electric Co., Ltd.	Vendor Artifact Hash:	
Address:	477, Bundangsuseo-ro, Bundang-gu, Seongnam-si, Gyeonggi-do, Republic of Korea	Umbrella Organization:	
Product:	HGMAP-BCS	Optional Reservation Test:	Yes
HW Version:	1.00	Serial Number:	BF23-01033
SW Version:	1.00	Publisher Legacy Variants:	-
Key Words:	Relay	Publisher Preferred Rates:	-
Test Procedure Version:	2.0.6	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	-
Certificate/Result Reviewer:	Herbert Falk	Subscriber Preferred Variants:	
Approval Date:	12/16/2023	Subscriber Preferred Rates:	-
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Korea Testing Laboratory (A)		

Description

Digital Monitoring and Protection Relay

History

#1 - 12/16/2023 10:49 AM - Herbert Falk

- Certificate Hash changed from 23-063447-01-1__HD Electric_HGMAP-BCS_Server_Ed2_Certification_KTL.pdf to SHA256: BE22CA352AC614B93C676F056EE29894143000695C71EBD3B589BED89CB6655A

Files

23-063447-01-1__HD Electric_HGMAP-BCS_Server_Ed2_Certification_KTL.pdf

12/16/2023

Herbert Falk