

## Server - Issues #665

### T1679 GoEna behavior at startup

04/20/2021 03:16 PM - Bruce Muschlitz

<b>Status:</b> Closed	<b>Due date:</b>
<b>Priority:</b> Normal	
<b>Assignee:</b> Bruce Muschlitz	
<b>Category:</b>	
<b>Target version:</b>	
<b>Discuss in Upcoming Meeting:</b> No	<b>Updated Test Document:</b> Server Ed2.1 TP1.2
<b>Clause Reference:</b>	<b>Test Case ID:</b> sGop3
<b>61850 Standard:</b> 7-2	<b>Closed Reason:</b> Test Procedure Update
<b>Triggering Tissue:</b> <a href="https://iec61850.tissue-db.com/tissue/1679">https://iec61850.tissue-db.com/tissue/1679</a>	<b>Triggering Tissue 2:</b>
<b>Final Decision:</b> See attachment 20210504	<b>Triggering Tissue 3:</b>
<b>Initial Test Document:</b> <a href="http://www.ucaiug.org/org/TechnicalO/Testing/UCAlug%20Testing%20Quality%20Assurance%20Program/Current%20IEC%2061850%20Edition%20%20Testing%20Procedures/UCATestProceduresServer61850-8-1Ed2Amd1_Rev1p0.pdf">http://www.ucaiug.org/org/TechnicalO/Testing/UCAlug%20Testing%20Quality%20Assurance%20Program/Current%20IEC%2061850%20Edition%20%20Testing%20Procedures/UCATestProceduresServer61850-8-1Ed2Amd1_Rev1p0.pdf</a>	

**Description**

Based upon TISSUE 1679, change expected startup value of GoEna from indeterminate to "true when GOOSE is well-configured:" (i.e. there is an implicit SetGoCBValues(GoEna,true) at startup but without any tracking trigger)

#### History

##### #1 - 05/04/2021 07:30 AM - Richard Schimmel

- Status changed from New to In Progress

##### #2 - 05/04/2021 08:41 AM - Bruce Muschlitz

- File TestProcedure\_sGop3\_20210504.docx added

- Status changed from In Progress to Resolved

- Final Decision set to See attachment 20210504

Added note that TICS needs update

##### #3 - 07/27/2021 09:06 AM - Richard Schimmel

- Subject changed from GoEna behavior at startup to T1679 GoEna behavior at startup

##### #4 - 06/02/2022 02:38 PM - Bruce Muschlitz

- Status changed from Resolved to Closed

- Updated Test Document set to Server Ed2.1 TP1.2

- Closed Reason Test Procedure Update added

- Closed Reason deleted (--Not Set--)

#### Files

TestProcedure_sGop3.docx	13.7 KB	04/20/2021	Bruce Muschlitz
TestProcedure_sGop3_20210504.docx	13.8 KB	05/04/2021	Bruce Muschlitz