

## Client - Issues #6654

### Tracking numbering mismatch Ed2 <> Ed2.1

12/18/2023 07:46 AM - Richard Schimmel

<b>Status:</b> Resolved	<b>Due date:</b> 01/23/2024
<b>Priority:</b> Normal	
<b>Assignee:</b> Richard Schimmel	
<b>Category:</b>	
<b>Target version:</b>	
<b>Discuss in Upcoming Meeting:</b> No	<b>Updated Test Document:</b>
<b>Clause Reference:</b>	<b>Test Case ID:</b> cTrk7...cTrk16
<b>61850 Standard:</b> 7-4	<b>Closed Reason:</b> --Not Set--
<b>Triggering Tissue:</b>	<b>Triggering Tissue 2:</b>
<b>Final Decision:</b>	<b>Triggering Tissue 3:</b>
<b>Initial Test Document:</b> Ed2Amd1 TP1.0	

#### Description

The tracking of the unicast sampled values (cTrk6) has been removed in Client Ed2.1 and the numbering adjusted e.g. former cTrk8 is now cTrk7.

I propose we keep the test case numbering consistent. as such the former cTrk8 stays cTrk8 etc.

Maybe we need keep the unicast sampled value tracking test case (not really clear why we removed this test case). The NTS is still mentioned in the MICS, cMdl3, sRp15/sBr15, sDs15

#### History

##### #1 - 01/09/2024 08:27 AM - IEC 61850 TPWG

- Due date set to 01/23/2024
- Status changed from New to Resolved
- Assignee set to Richard Schimmel

retire deprecated numbers without changing/reordering others. cTrk6 will be re-inserted as deprecated.

NTS needs to be cleaned in the documents and testcases mentioned.