

IEC 61850 Certificate - IEC 61850 Certificate #6659

CSI-200E-ER

12/28/2023 08:15 AM - Herbert Falk

Status:	Approved	
Priority:	Normal	
61850 Edition:	Edition 2	Certificate Name: BEIJING SIFANG AUTOMATION CO., LTD. _ CSI-200E-ER_ Remote Terminal Unit(RTU)_2023PUCA000008_KETOP.pdf
61850 Tested Aspects:	Server	Certificate Hash: SHA256: 2B0A20B32A86CA0355908186164D792A89DAC3E1121FD5CE659C8482820B665D
Company:	BEIJING SIFANG AUTOMATION CO.,LTD	Vendor Artifact File Name:
Address:	Number9, Shangdi 4th Street, Haidian District, Beijing, P.R.C.100085	Vendor Artifact Hash:
Product:	CSI-200E-ER	Umbrella Organization:
HW Version:	V1.0	Optional Reservation Test: Yes
SW Version:	V1.0.1	Serial Number:
Key Words:	RTU	Publisher Legacy Variants: -
Test Procedure Version:	2.0.6	Publisher Preferred Rates: -
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), SBO Control (12b), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Publisher Preferred Variants:
Certificate/Result Reviewer:	Herbert Falk	Subscriber Legacy Variants: -
Approval Date:	12/28/2023	Subscriber Preferred Variants:
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Subscriber Preferred Rates: -
Current Test Lab Name:	Xuchang KETOP Testing Research Institute Co.(A)	Product Variants:
Test Document:	Edition 2 Server Test Procedures version 2.0.6	Time Activated Control:
Description CSI-200E-ER RTU (Remote Teminal Unit) is widely applied to power grid.hydropower, oil and gas, water conservancy, municipal, etc.		

Files

BEIJING SIFANG AUTOMATION CO., LTD. _ CSI-200E-ER_ Remote Terminal Unit(RTU)_2023PUCA000008_KETOP.pdf	Herbert Falk
---	--------------