

IEC 61850 Certificate - IEC 61850 Certificate #6661

REX615

12/28/2023 08:38 AM - Herbert Falk

Status:	Approved	Test Document:	Edition 2 with Amendment 1 Server Test Procedures version 1.2
Priority:	Normal	Certificate Name:	23-3355_DNV_ABB_REX615_ServerEd2Amd1_Certificate.pdf
61850 Edition:	Edition 2 Amd 1	Certificate Hash:	SHA256: D7E75438965AE9C23C55F4E7997C9D 357E061B59BED7F3FBDD5CF5973CC 2DAFE
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	ABB Oy Distribution Solutions	Vendor Artifact Hash:	
Address:	Muottitie 2A F1-65101 VAASA Finland	Umbrella Organization:	
Product:	REX615	Optional Reservation Test:	Yes
HW Version:		Serial Number:	1VHA123456R2
SW Version:	6.0	Publisher Legacy Variants:	-
Key Words:		Publisher Preferred Rates:	-
Test Procedure Version:	1.2	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1a), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Time sync PTP (B13b), Time sync SNTP (B13a), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	-
Certificate/Result Reviewer:	Herbert Falk	Subscriber Preferred Variants:	
Approval Date:	12/28/2023	Subscriber Preferred Rates:	-
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			

Files

23-3355_DNV_ABB_REX615_ServerEd2Amd1_Certificate.pdf	101 KB	12/28/2023	Herbert Falk
--	--------	------------	--------------