

IEC 61850 Certificate - IEC 61850 Certificate #6662

PowerLogic™ P7

12/28/2023 08:44 AM - Herbert Falk

Status:	Approved	Certificate Name:	23-3104_DNV_Schneider_P7_ServerEd2Amd1_Certificate.pdf
Priority:	Normal	Certificate Hash:	SHA256: 05269955F39FA2C713F17E05F1D1D06 44E89C0183429ECD030B38A5F1DF2F 041
61850 Edition:	Edition 2 Amd 1	Vendor Artifact File Name:	
61850 Tested Aspects:	Server	Vendor Artifact Hash:	
Company:	Schneider Electric Industries SAS	Umbrella Organization:	Schneider
Address:	"35 rue Joseph Monier 92500 Rueil Malmaison France"	Optional Reservation Test:	No
Product:	PowerLogic™ P7	Serial Number:	WX221110005
HW Version:		Publisher Legacy Variants:	-
SW Version:	V02.001	Publisher Preferred Rates:	-
Key Words:		Publisher Preferred Variants:	
Test Procedure Version:	1.2	Subscriber Legacy Variants:	-
IEC 61850 Blocks Certified:	Basic Exchange (B1a), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), Service Tracking (B15), Setting Group (B4), Setting Group Definition (B4+), Time sync PTP (B13b), Time sync SNTP (B13a), Unbuffered Reporting (B5)	Subscriber Preferred Variants:	
Certificate/Result Reviewer:	Herbert Falk	Subscriber Preferred Rates:	-
Approval Date:	12/28/2023	Product Variants:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Time Activated Control:	
Current Test Lab Name:	DNV Netherlands (A)		
Test Document:	Edition 2 with Amendment 1 Server Test Procedures version 1.2		
Description			

Files

23-3104_DNV_Schneider_P7_ServerEd2Amd1_Certificate.pdf	109 KB	12/28/2023	Herbert Falk
--	--------	------------	--------------