

# IEC 61850 Certificate - IEC 61850 Certificate #6673

## G-ISD

01/08/2024 09:12 AM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	Edition 2 Client Test Procedures version 1.2
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	23-038344-01-1_G-ISD_Genad System_Client_Ed2_TP_1p2_Certificate_KTL.pdf
<b>61850 Edition:</b>	Edition 2	<b>Certificate Hash:</b>	SHA256: 1CE54D05E9DC03E6EEC06B774E969 5040F1857A0584D1EC580E34616448E D57C
<b>61850 Tested Aspects:</b>	Client	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	Genad System Co.,Ltd.	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	78, Hyeoksinsandan 5-gil, Naju-si, Jeollanam-do, Republic of Korea	<b>Umbrella Organization:</b>	
<b>Product:</b>	G-ISD	<b>Optional Reservation Test:</b>	No
<b>HW Version:</b>	1 (HPE DL380 Gen10)	<b>Serial Number:</b>	2023-ISD-001
<b>SW Version:</b>	1 (Ubuntu 22.04.3 LTS)	<b>Publisher Legacy Variants:</b>	-
<b>Key Words:</b>		<b>Publisher Preferred Rates:</b>	-
<b>Test Procedure Version:</b>	1.2	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), SBO Control (12b), Service Tracking (B15), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	-
<b>Certificate/Result Reviewer:</b>	Herbert Falk	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	01/08/2024	<b>Subscriber Preferred Rates:</b>	-
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	Korea Testing Laboratory (A)		
<b>Description</b> xGrids Transfer			

### Files

23-038344-01-1\_G-ISD\_Genad System\_Client\_Ed2\_TP\_1p2\_Certificate\_KTL.pdf 59 KB 01/08/2024 Herbert Falk