

IEC 61850 Certificate - IEC 61850 Certificate #6675

Prometer 100

01/13/2024 08:27 AM - Herbert Falk

Status:	Approved	Test Document:	Edition 2 Server Test Procedures verisons 2.0.6
Priority:	Normal	Certificate Name:	CPRI-SECURE METERS Sweden AB_CPRIBLRSGRL24TC0002_Certificate.pdf
61850 Edition:	Edition 2	Certificate Hash:	SHA256: 52C8F14FBB468D4B25D7ECC6849C9 BCED3EA12436BA51CAFD881E8AAE2 2E033D
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	SHA256: 52C8F14FBB468D4B25D7ECC6849C9 BCED3EA12436BA51CAFD881E8AAE2 2E033D	Vendor Artifact Hash:	SHA256: 52C8F14FBB468D4B25D7ECC6849C9 BCED3EA12436BA51CAFD881E8AAE2 2E033D
Address:	Secure Meters (Sweden) AB, Västra Kvarngatan 62, SE- 611 32 Nyköping, Sweden (A Secure Meters Limited , Udaipur , India Group Company)	Umbrella Organization:	
Product:	Prometer 100	Optional Reservation Test:	No
HW Version:	003,005	Serial Number:	WP062090
SW Version:	0.16	Publisher Legacy Variants:	-
Key Words:	Meter	Publisher Preferred Rates:	-
Test Procedure Version:	2.0.6	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	-
Certificate/Result Reviewer:	Herbert Falk	Subscriber Preferred Variants:	
Approval Date:	01/13/2024	Subscriber Preferred Rates:	-
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Central Power Research Institute India (A)		
Description			
3 Phase Energy meter with communication interface (3P4W/3P3W)			

Files

CPRI-SECURE METERS Sweden AB_CPRIBLRSGRL24TC0002_Certificate.pdf 780 KB 01/13/2024 Herbert Falk