

# IEC 61850 Certificate - IEC 61850 Certificate #6676

## P841 (GE MiCOM Agile P841)

01/13/2024 08:36 AM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	Edition 2 Server Test Procedures version 2.0.6
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	50745.6841.803_GE_P841_AAN_Ed2_Certificate.pdf
<b>61850 Edition:</b>	Edition 2	<b>Certificate Hash:</b>	SHA256: 6C411A137A55E51783F68CD90473FF BE9036ACF17ED5F2DA5FC95B840767 697E
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	GE Renewable Energy Ltd.	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	St. Leonards Building, Harry Kerr Drive Stafford, ST16 1WT United Kingdom	<b>Umbrella Organization:</b>	
<b>Product:</b>	P841 (GE MiCOM Agile P841)	<b>Optional Reservation Test:</b>	Yes
<b>HW Version:</b>	Q	<b>Serial Number:</b>	
<b>SW Version:</b>	AAN	<b>Publisher Legacy Variants:</b>	-
<b>Key Words:</b>	Relay	<b>Publisher Preferred Rates:</b>	-
<b>Test Procedure Version:</b>	2.0.6	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	-
<b>Certificate/Result Reviewer:</b>	Herbert Falk	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	01/13/2024	<b>Subscriber Preferred Rates:</b>	-
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	Grid Automation Laboratories (B)		
<b>Description</b> GE MiCOM Agile P841 Multifunction Line Terminal IED			

### History

#1 - 01/13/2024 08:37 AM - Herbert Falk

- *Optional Reservation Test changed from No to Yes*

### Files

50745.6841.803_GE_P841_AAN_Ed2_Certificate.pdf	227 KB	01/13/2024	Herbert Falk
--	--------	------------	--------------