

WG14 Part 11 Issues - CIM Issues #6678

Refactoring Outage Class Modeling

01/16/2024 11:45 AM - Henry Dotson

Status: New	
Priority: Normal	
Target version:	
Author/Contact Info: Henry B. Dotson, III	Standard(s):
Base Release: CIM101	Version:
Solution to be Applied To: CIM101	Clause:
Solution Version: CIM101	Sub-Clause:
Solution Applied By:	Paragraph:
Completion Date:	Table:
CIM Keywords: 61968-Common, 61968-Operations	Originally Closed in Version:
Breaking Change:	Origination Date:
Breaking Change Description:	Origination ID:
CIM Impacted Groups: WG14	Originally Assigned To:
Requestor:	
Description Currently the Outage class inherits from the Document class. This modeling is not semantically correct because an outage is not a document, it is an event. Therefore, the modeling should be refactored to correctly express the intended semantics.	
Proposed Solution Have Outage inherit from IdentifiedObject and create an association between Outage and ActivityRecord.	