

IEC 61850 Certificate - IEC 61850 Certificate #6682

NS3560

01/21/2024 10:57 AM - Herbert Falk

Status:	Approved	Test Document:	Edition 2 Server Test Procedures version 2.0.6
Priority:	Normal	Certificate Name:	24-4012_DNV_NARI Technology_NS3560_ServerEd2_Certificate.pdf
61850 Edition:	Edition 2	Certificate Hash:	SHA256: 6B7D8BA709ADA050E04158C1272603 617165B6B2D5E3BA3A13D57F83720F DEC9
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	NARI Technology Co., Ltd.	Vendor Artifact Hash:	
Address:	Industrial Building 3rd Floor No.19 Chengxin Avenue 211106 Nanjing People's Republic of China	Umbrella Organization:	
Product:	NS3560	Optional Reservation Test:	Yes
HW Version:		Serial Number:	70000045016005150909010020220629 000843
SW Version:	V1.02	Publisher Legacy Variants:	-
Key Words:		Publisher Preferred Rates:	-
Test Procedure Version:	2.0.6	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	-
Certificate/Result Reviewer:	Herbert Falk	Subscriber Preferred Variants:	
Approval Date:	01/21/2024	Subscriber Preferred Rates:	-
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			

History

#1 - 01/22/2024 07:08 AM - Herbert Falk

- Optional Reservation Test changed from No to Yes

- Serial Number changed from 700000450160051 to 70000045016005150909010020220629000843

Files

24-4012_DNV_NARI Technology_NS3560_ServerEd2_Certificate.pdf 104 KB

01/21/2024

Herbert Falk