

61850-7-5 and 61850-7-500 - IEC61850-7-5 #6684

Proposal to deprecate 'LocSta' in X and Y group LN classes

01/22/2024 02:50 AM - Michael Haecker

Status:	New	Start date:	01/22/2024
Priority:	Normal	Due date:	
Assignee:	Manager61850-7-500	% Done:	0%
Category:			
Target version:			
Source:	discussion	TF 7-5 Project document:	IEC 61850-7-500
Category:	Not yet categorized	Related TISSUE:	
Description			
<p>It is the purpose of 'LocSta' to define the level of control authority (remote control center vs. substation). Since controls are to be managed by the corresponding CSWI LN instances, A-group LN instances respectively, control commands are not managed by X and Y class LN instances.</p> <p>It is proposed to deprecate 'LocSta' in X and Y group LN classes.</p>			