

## GOOSE Performance - Issues #6685

### Device need to be certified for Ed2.1 server first

01/23/2024 09:21 AM - Richard Schimmel

|                                        |                                   |
|----------------------------------------|-----------------------------------|
| <b>Status:</b> In Progress             | <b>Due date:</b> 04/30/2024       |
| <b>Priority:</b> Normal                |                                   |
| <b>Assignee:</b> Herbert Falk          |                                   |
| <b>Category:</b>                       |                                   |
| <b>Target version:</b>                 |                                   |
| <b>Discuss in Upcoming Meeting:</b> No | <b>Updated Test Document:</b>     |
| <b>Clause Reference:</b>               | <b>Test Case ID:</b>              |
| <b>61850 Standard:</b>                 | <b>Closed Reason:</b> --Not Set-- |
| <b>Triggering Tissue:</b>              | <b>Triggering Tissue 2:</b>       |
| <b>Final Decision:</b>                 | <b>Triggering Tissue 3:</b>       |
| <b>Initial Test Document:</b> GPF 2.5  |                                   |

#### Description

We need to add a requirement in the GOOSE performance test procedures that the DUT has passed the server conformance test before it can pass the GOOSE performance test (for the same edition). For example it's not allowed that an Ed2 certified server receives an Ed2.1 GOOSE performance certificate.

Proposal update 4.3 last sentence to: The DUT has passed the GOOSE performance test when all test cases are passed **and it has passed the server conformance test for the same edition**

Similar for test lab accreditation: the test lab is only allowed to issue Goose performance certificates when it has been accredited for server as well. WE propose to updated the QAP.

#### History

##### #1 - 02/20/2024 08:50 AM - IEC 61850 TPWG

- Due date set to 04/02/2024

- Status changed from New to In Progress

- Assignee set to Herbert Falk

Accepted.

This goes in accreditation docs rather than QAP.

##### #2 - 04/02/2024 08:44 AM - IEC 61850 TPWG

- Due date changed from 04/02/2024 to 04/16/2024

Herb to update.

##### #3 - 04/16/2024 08:43 AM - IEC 61850 TPWG

- Due date changed from 04/16/2024 to 04/30/2024