

IEC 61850 Certificate - IEC 61850 Certificate #6691

PowerLogic™ P3U30

02/03/2024 10:55 AM - Herbert Falk

Status:	Approved	Test Document:	Edition 2 Server Test Procedures version 2.0.6
Priority:	Normal	Certificate Name:	SchneiderElectric_PowerLogicP3U30_30.208_ServerEd2_Certificate.pdf
61850 Edition:	Edition 2	Certificate Hash:	SHA256: 8FF7748F7EFC11B8491D563E0F70E5 4BF5F768D2CEACCAD6E578A5F36F1 FE42E
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Schneider Electric Industries SAS	Vendor Artifact Hash:	
Address:	35 rue Joseph Monier, 92500 Rueil -Maimaison, France	Umbrella Organization:	
Product:	PowerLogic™ P3U30	Optional Reservation Test:	Yes
HW Version:	WX202240036	Serial Number:	WX202240036
SW Version:	V30.208	Publisher Legacy Variants:	-
Key Words:	Relay	Publisher Preferred Rates:	-
Test Procedure Version:	2.0.6	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	-
Certificate/Result Reviewer:	Herbert Falk	Subscriber Preferred Variants:	
Approval Date:	02/03/2024	Subscriber Preferred Rates:	-
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Schneider-Electric China (B)		
Description			

Files

SchneiderElectric_PowerLogicP3U30_30.208_ServerEd2_Certificate.pdf 54 KB

02/03/2024

Herbert Falk