

61850-7-5 and 61850-7-500 - IEC61850-7-5 #6698

Integrate work from AHTF Control Between Functions

02/07/2024 02:08 AM - Keith Gray

Status: New	Start date: 02/07/2024
Priority: Normal	Due date:
Assignee:	% Done: 0%
Category:	
Target version:	
Source:	TF 7-5 Project document: IEC 61850-7-5, IEC 61850-7-500
Category: Not yet categorized	Related TISSUE:
Description Collect the work created by this AHTF and integrate it into 7-5 and 7-500. We need to locate the latest draft of the document, review that draft, and determine how to integrate it with our documents.	

History

#1 - 02/07/2024 02:29 AM - Tom Berry

One of the issues is that MMS control service status and results are not visible in IED device models.

For a distribution automation application I added data objects

CILO or

CSWI OpStr control in progress

SSWI OpTmAlm control failure (timeout)

SSWI OpErrCod control result (cause)