

# IEC 61850 Certificate - IEC 61850 Certificate #6705

## VIPAMj3500II-TR

02/10/2024 10:43 AM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	Edition 2 Server Test Procedures version 2.0.6
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	24TC200102_VitzroEM_IED_VIPAM3500II-TR_Server_Ed2_KERI.pdf
<b>61850 Edition:</b>	Edition 2	<b>Certificate Hash:</b>	SHA256: 9B65383C9A394A805F149180DC9CFD BE0D8B771FCD1D7CB0FB5CF56C5C2 9A1A4
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	VITZRO EM Co., Ltd.	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	Vitzro Bldg, 7, Neungdong-ro, 25-gil, Gwangjin-gu, Seoul, 22663, Republic of Korea	<b>Umbrella Organization:</b>	
<b>Product:</b>	VIPAMj3500II-TR	<b>Optional Reservation Test:</b>	Yes
<b>HW Version:</b>	1.000	<b>Serial Number:</b>	76899418400002
<b>SW Version:</b>	1.000	<b>Publisher Legacy Variants:</b>	-
<b>Key Words:</b>		<b>Publisher Preferred Rates:</b>	-
<b>Test Procedure Version:</b>	2.0.6	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), Service Tracking (B15), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	-
<b>Certificate/Result Reviewer:</b>	Herbert Falk	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	02/10/2024	<b>Subscriber Preferred Rates:</b>	-
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	Korea Electrotechnology Research Institute (A)		
<b>Description</b>			
Protection and control			

### Files

24TC200102\_VitzroEM\_IED\_VIPAM3500II-TR\_Server\_Ed2\_KERI.pdf 711 KB

02/10/2024

Herbert Falk